

OPEN VIOLATIONS

PLEASE REFER TO THE PERMIT INFORMATION AT THE END OF THIS REPORT FOR CORRECTIVE ACTIONS WITH A FOOTNOTE OF a "P" or "M". ANY VIOLATION CITED IN THIS REPORT SHALL BE CORRECTED AND SHALL BE MAINTAINED AND/OR KEPT IN AN OPERATIVE CONDITION AT ALL TIMES PURSUANT TO N.J.A.C. 5:10-1.6 AND/OR N.J.A.C. 5:70 ET SEQ.

Violation ID	Bldg #	Area	Location	Corrective Action	Life Safety
4469437	Building 1 1111 RIVER RD UNIT E-H	Building 1 - Common	Basement-all crawl spaces	Provide ventilation crawl space to prevent the accumulations of moisture and dampness. *M [N.J.A.C. 5:10-8.1(a)]	N
4469439	Building 1 1111 RIVER RD UNIT E-H	Building 1 - Common	Basement-all crawl spaces	Extension cords must not be used in place of permanent wiring. *M [N.J.A.C. 5:70-3,605.5]	Y
4469438	Building 1 1111 RIVER RD UNIT E-H	Building 1 - Common	Basement-all crawl spaces	Waterproof crawl space to prevent the penetration of Water or other Sources of Moisture. [N.J.A.C. 5:10-8.1(a)]	N

UNITS/AREAS WITH NO VIOLATIONS

Bldg #	Area
